

August 2009

MEMORANDUM

TO: All Employees

FROM: Lisa Kao, Manager
Office of Environmental Health and Safety

SUBJECT: Asbestos Notification

This notification is being made to inform you of the location of campus building components that may or are known to contain asbestos. The University continues to survey locations for the presence of asbestos-containing material prior to any work that may disturb building materials, and already identified ACM is routinely inspected to ensure the integrity of the material. Asbestos fibers are commonly found in many building components, examples include: thermal system insulation, roofing materials, floor tile, fire doors, laboratory benchtops, chalkboards, spray-on insulation, sheet rock “mud” and plaster, mastic and glues.

Please note that asbestos fibers are only a health hazard if they become airborne in sufficient numbers due to material aging, deterioration, or as the result of some damage. Since asbestos is only a hazard if airborne, it is important for employees to follow proper work practices to minimize the potential for disturbing ACM. Only persons who have been trained and certified are authorized to perform work that may disturb asbestos fibers. Building materials in buildings constructed prior to 1981 must be presumed to be ACM until laboratory testing can confirm otherwise.

If you observe any asbestos materials that have been damaged, report the condition immediately to your supervisor or the Office of EH&S. Do not disturb damaged asbestos debris or materials.

A listing of all specific locations known to contain asbestos is presented on the following pages. Any employee may review the asbestos survey data used to compile this listing. Data is available during normal business hours at the Office of Environmental Health and Safety. If you have any questions, or would like to request additional information, please do not hesitate to contact me at (559) 278-6910.

Attachment

BUILDING LOCATION OF ASBESTOS CONTAINING MATERIALS (ACBM)

AC = Acoustical Ceiling; CT = Ceiling Tile; CM = Ceiling mastic; CVM = Coving mastic;
 CWP = Crawlspace plaster; DWM = Drywall mud; FD = Fire Door, FT = Floor Tile;
 PL = Pipe lagging; RF = Roof; TT = Table Top; SW = Stucco Walls; W = Window Casements;
 WB = Wallboard/Plaster; FH = Fume Hood Transite Panels

Updated: August 2009

BUILDING	TYPE OF ASBESTOS
1. Joyal Administration	PL, FT, RF, DWM
2. Music	FD, CM
3. Speech Arts	PL, FT, RF, CWP
4. Conley Art	PL, FT, RF, FD, DWM
5. Conley Art – Print Facility	RF, FH
6. Agriculture Science Building	FT, PL, RF, TT, DWM, FH
7. Ag Mechanics	FT, RF, PL, DWM, SW
8. Psychology/Human Services	AC, CT, PL, FD, FT, RF
9. Family & Food Sciences	PL, FT, RF, FD, DWM
10. McKee Fisk	PL, FT, FD, RF, DWM, WB, CM
11. Social Science	PL, FT, RF
12. Engineering West	PL, FT, RF, FD, DWM, FH
13. Engineering East	PL, AC, FT, FD, DWM, CVM, CT, FH
14. Grosse Industrial Technology	PL, FT, RF, TT, DWM, CM, WB, FH
15. McLane Hall	FT, PL, DWM, FH
16. North Gymnasium	PL, FT, RF, DWM, CM
17. South Gymnasium	PL, FT, DWM, CVM
18. Science	FT, PL, TT, FD, FH
19. Biology Greenhouse	PL, RF
20. Madden Library	FT, PL, RF
21. Laboratory School	FT, PL, RF, FD
22. Kennel Bookstore	RF, PL
23. Thomas Administration	PL, FT
24. University Student Union	AC, PL, RF
25. Satellite Student Union	RF, PL
26. Plant Operations	PL, DWM, FT
27. Ag Operations	PL
28. Dairy Processing	PL
28a. Food Processing Building	PL, RF
28b. Dairy Feed Shelter Barn	RF
29. Sheep Unit	PL, FT, RF
30. Meat Laboratory	PL, RF
31. Meat Laboratory Annex	PL, RF
32. Post Harvest Laboratory	FT, RF, PL

33. Beef Unit	PL, RF
34. Veterinary Hospital	PL, RF
35. Swine Unit	PL
36. Central Unit	PL
37. Commons (Housing)	PL, FT
37a. Aspen/Ponderosa	FT, FR, PL
37b. Baker	PL, FT, FD, RF
37c. Birch	RF, FT
37d. Graves	FT, PL, FD, RF
37e. Homan	FT, PL, FD, RF
37f. Sequoia/Cedar	FT, RF
37g. Sycamore	FT, RF, PL
38. Cafeteria	FT, AC, PL, RF, FD
39. Student Health Center	PL, RF
40. Resident Dining Hall	FT, PL, RF, FD
41. Print Shop/Warehouse	RF
42. Duncan Athletic	FD
43. Keats Campus	FT, RF, DWM
44. Round-up Field Lab	PL, RF, TT, FH
45. Public Safety	RF, FT, DWM
46. Animal Physiology Lab	FT, RF
47. Feed Mill	PL
48. CIT Center Farm Market	FT, PL, RF
49. Viticulture Research	FT, TT, DWM
50. Viticulture Field House	FT, DWM
51. Raisin Processing Lab	FT, DWM
52. Enology	FT, PL, DWM, WB, CVM
53. Livestock Judging Pavilion	PL
54. CATI Headquarters	RF, PL
55. CATI Storage Facility	RF
56. OH Head House	FT
57. OH Glass House 1	PL
58. OH Glass House 2	PL
59. OH Glass House 3	PL
60. Orchard Equip. Storage	DWM
61. Agronomy Field Lab	TT, DWM

Special Findings:

Areas determined to potentially contain an airborne asbestos hazard and require special precautions and permission from Office of EHS prior to entrance:

- Ag Science (above ceiling/attic spaces/crawl space under building)
- University Center (above ceiling/attic spaces)
- North Gym (ceiling/attic spaces)
- Old Cafeteria Building (Main kitchen, Main kitchen storeroom)